

EDMONTON WATER WORKS

2024 Water Quality Report

1/1/2024-12/31/2024

Water System ID: KY0850115
Superintendent: Moe Hensley
Phone: 270-432-4844
CCR Contact: Moe Hensley
Phone: 270-432-4844



Mailing Address: P.O. Box 374
Edmonton, KY 42129
Meeting Address: City Hall, 207 East St.
Edmonton, KY 42129
Time: 1st Monday of each month, 4:00pm

This report is designed to inform the public about the quality of water and service provided by Edmonton Water Works on a daily basis. Our commitment is to provide our customers with a safe, clean and reliable product each time the tap is turned on. We want you to know that we stay in touch with our suppliers and assure you that we will continue to monitor, protect and improve our water system to deliver a high-quality product to each and every Edmonton Water Works customer.

In 2024, Edmonton Water Works purchased water from two sources. One of these is the Glasgow Water Company which has two water treatment plants within Barren County. The "Summer Shade" plant on the table page refers to the treatment plant located in Lucas, Kentucky which treats water from the Barren River Reservoir. The "Edmonton" plant on the table page refers to the treatment plant located in Glasgow, Kentucky which treats water from Beaver Creek. Edmonton Water Works also purchases water from the Columbia-Adair Utilities District. All of these water sources come from surface water. Source water assessments with a summary of the systems' susceptibility to potential sources of contamination have been completed and indicate that this susceptibility is moderate. Sources of potential contamination include active oil wells, gas wells, underground storage tanks and agricultural chemicals. That plan is available for inspection at Barren River Area Development District located at 177 Graham Avenue, Bowling Green, KY 42102-9005 or, by telephone, (270) 781-2381.

The majority of our water comes from the Glasgow Water Company. We purchase through two points, one at 68-80 and the other on Hwy 90. This serves all of our system with the exception of the Mosby Ridge Rd area, Mosby Ridge Rd. to the Adair county line (on Hwy 68), Lewis Free Rd. to the Adair County line (Hwy 533) and the Reece Hurt Rd area. These areas are supplied by Columbia/Adair Utilities and we have two purchase points with them as well. All of our purchased water comes from surface water.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your local water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Service Line Inventory Information:

To address lead in drinking water, EPA requires that all community water systems develop and maintain an inventory of service line materials. We have not completed our service line inventory (SLI) at this time. We are still working on it, and it can be viewed on our website at www.cityofedmontonky.com, going to the "Water" page and clicking on "Service Line Inventory Public Map".

Lead Sample Results Availability Information:

We are required to periodically sample water from customer taps to determine lead and copper levels. EPA sets the lead action level at 0.015 mg/L (15 ppb). For a water system to be in compliance, at least 90% of tap water samples must have lead levels below this limit. This report contains the 90th percentile and range of our most recent sampling. The individual results for each location sampled can be reviewed at our office.

We are only required to test for some contaminants periodically, so the results listed in this report may not be from the previous year. Only detected contaminants are included in this report. For a list of all contaminants we test for please contact us. Copies of this report are available upon request by contacting our office at 207 East St, Edmonton, KY, or by calling 270-432-4844.

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variances & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

Reports will not be mailed unless requested. Additional copies may be obtained by visiting Edmonton Water Works at 207 East St., Edmonton, KY, by calling 270-432-4844 or by visiting our website at www.cityofedmontonky.com.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. **Copies of this report are available upon request by contacting our office during business hours.**

A=Glasgow(Summer Shade) B=Glasgow(Edmonton) C=Columbia-Adair D=Edmonton									
Regulated Contaminant Test Results									
Contaminant [code] (units)	MCL	MCLG	Source	Report Level	Range of Detection		Date of Sample	Violation	Likely Source of Contamination
Inorganic Contaminants									
Barium [1010] (ppm)	2	2	A= B= C=	0.028 0.033 0.02	0.028 to 0.033 to 0.02 to	0.028 0.033 0.02	Feb-24 Feb-24 Apr-24	NO NO NO	Drilling wastes; metal refineries; erosion of natural deposits
Fluoride [1025] (ppm)	4	4	A= B= C=	0.71 0.57 0.79	0.71 to 0.57 to 0.79 to	0.71 0.57 0.79	Feb-24 Feb-24 Apr-24	NO NO NO	Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	A= B=	2.34 2.22	2.34 to 2.22 to	2.34 2.22	Feb-24 Feb-24	NO NO	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants/Disinfection Byproducts and Precursors									
Total Organic Carbon (ppm) (report level=lowest avg. range of monthly ratios)	TT*	N/A	A= B= C=	1.89 2.22 1.17	1.55 to 1.59 to 0.97 to	3.17 3.5 1.45	2024 2024 2024	NO NO NO	Naturally present in environment.
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.									
Chlorine (ppm)	MRDL = 4	MRDLG = 4		1.00 (highest average)	0.29 to	1.71	2024	NO	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	D=	46 (average)	24 to	73 (range of individual sites)	2024	NO	Byproduct of drinking water disinfection
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	D=	54 (average)	25 to	63 (range of individual sites)	2024	NO	Byproduct of drinking water disinfection.
Household Plumbing Contaminants									
Copper (ppm) Round 1 sites exceeding action level 0	AL = 1.3	1.3	D=	0.034 (90 th percentile)	0 to	0.206	Aug-23	NO	Corrosion of household plumbing systems
Lead (ppb) Round 1 sites exceeding action level 0	AL = 15	0	D=	0 (90 th percentile)	0 to	7	Aug-23	NO	Corrosion of household plumbing systems
Other Constituents									
Turbidity (NTU) TT * Representative samples	Allowable Levels		Source	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity		
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU Less than 0.3 NTU in 95% monthly samples	A= B= C=		0.099 0.093 0.09	100 100 100	NO NO NO	Soil runoff		

Your drinking water has been sampled for a series of unregulated contaminants. Unregulated contaminants are those that EPA has not established drinking water standards. There are no MCLs and therefore no violations if found. The purpose of monitoring for these contaminants is to help EPA determine where the contaminants occur and whether they should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact our office during normal business hours.

Fluoride (added for dental health)	A= B= C=	Average	Range of Detection	
		0.75	0.67 to	0.87
		0.76	0.64 to	0.97
Sodium (EPA guidance level = 20 r	A= B=	0.79	0.79 to	0.79
		3.30	3.3 to	3.3
		7.60	7.6 to	7.6